



Product certificate K107103/01

Issued 2021-10-15

Replaces -

Page 1 of 2

Akdolit® CM G (Akdolit-Gran)

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Lhoist Germany Rheinkalk GmbH

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with the Kiwa Guideline BRL-K15003 "Evaluation Guideline for the Kiwa product certificate for products used for treatment and/or production of drinking water", dated 25-10-2016.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

579171015

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.com
www.kiwa.com

Company
Lhoist Germany
Rheinkalk GmbH
Am Kalkstein 1
D-42489 Wülfrath
Germany
Tel. +49 (0)2058 170
www.lhoist.com/de_de

Production location - Istein
Lhoist Germany
Rheinkalk GmbH
Am Kehrenweg 10
D-79588 Efringen-Kirchen
Germany
Tel. +49 (0)7628 260



**Certification process
consists of initial and
regular assessment of:**

- quality system
- product

Akdolit® CM G (Akdolit-Gran)

PRODUCT SPECIFICATION

This certificate covers conditioning agent with the brand name 'Akdolit® CM G (Akdolit-Gran)'.

PRODUCT REQUIREMENTS

The products as described in this certificate comply with BRL K15003, including the requirements as specified in:

NEN-EN 1018: Chemicals used for treatment of water intended for human consumption – Calcium carbonate

NEN-EN 16004: Chemicals used for treatment of water intended for human consumption – Magnesium oxide

FITNESS FOR CONTACT WITH DRINKING WATER

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation", dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects. The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate

MARKING

Design of the required Kiwa certification mark:

- "kiwa ", in ink or seal.

Location of the mark:

- On the packaging / On the delivery receipt.

Mandatory marks:

- "kiwa ";
- "Akdolit® CM G (Akdolit-Gran)";
- "K107103".

APPLICATION AND USE

Akdolit® CM G (Akdolit-Gran) is used as filtering materials for deacidification, iron and manganese removal, and/or softening of mains water.

REMAINING CONDITIONS

The means for and the way of transportation, storage and packaging have to be in accordance with the directives as given by the consumer, taking into consideration the use of the product. (These guidelines are not a part of the hygienic criteria.)

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Lhoist Germany Rheinkalk GmbH

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's (processing) guidelines for the proper storage and transport methods.

Check whether this certificate is still valid by consulting www.kiwa.com.